



19 North Main Street • Temple, TX 76501 • (254) 773-3731
800 South Austin Ave • Georgetown, TX 78626 • (512) 819-9478

February 11, 2025

Mr. Ed Kolacki
Senior Project Manager
3210 E. Avenue H Building A
Temple, Texas 76501

Re: City of Temple, Texas
24th Street Overpass and Pedestrian Improvements – Change Order #3

Dear Mr. Kolacki:

I am writing to formally submit Change Order #3 for the 24th Street Overpass and Pedestrian Improvements Project, which involves utilizing the existing outside concrete rails for the BNSF required fencing over the BNSF right-of-way and painting the rails with anti-graffiti paint.

The BNSF construction service team required any demolition of the existing concrete barrier rail to incorporate steel plates on the rail infrastructure below. With the area in the right-of-way being the BNSF fueling yard, this would not be a practice construction method to complete the project. Due to these requirements the project will utilize the existing concrete barrier and attach the required fencing to the existing concrete rail. Anti-graffiti paint will be applied to all rails on the project with the City of Temple picking the color of the paint. The unit prices for this change order are consistent with typical costs for this type of work.

We are in agreement with the proposal to utilize the existing concrete barrier rail for fencing over the BNSF right-of-way.. The effect on the project is a deduct in the amount of \$96,205.00.

We have reviewed Change Order #3 and recommend it be processed and executed with respect to the Patin Construction, LLC's contract for the above referenced project.

Sincerely,

A handwritten signature in blue ink, appearing to read 'R. David Patrick', is written in a cursive style.

R. David Patrick, P.E., CFM
President & CEO
dpatrick@kpaengineers.com